



**Intertek**

PROGRAM ADMINISTRATOR  
DEPARTMENT ALECP  
INTERTEK  
3933 U.S. ROUTE 11  
CORTLAND, NY 13045-0950

REVISION DATE: August 9, 2011

ORIGINAL ISSUE DATE: March 28, 2011

Recertification due: September 2018

An Activity Sponsored and Administered by  
Intertek

UNIKA UNIVERSAL KABLO SANAYI VE TIC A.S.  
Velikoy Sanai Bolgesi  
Sanayi Mah 3 Cadde No. 4  
Velikoy Gerkezkoy  
Tekirdag, Turkey 59550

**AIRPORT LIGHTING  
EQUIPMENT  
CERTIFICATION PROGRAM**

**CERTIFICATE OF  
CONFORMANCE**

The product described below is hereby approved for listing in the next issue of the Federal Aviation Administration (FAA) Advisory Circular (AC) 150/5345-53, Appendix 3 Addendum "Airport Lighting Equipment Certification Program. The approval is based on successful completion of tests in accordance with the specifications listed in, and the requirements for approval described in the Advisory Circular, and the reporting to the Program Administrator the results of such tests, accompanied by related documents by an Intertek recognized testing laboratory. The certification is not valid for a product modified with non-OEM replacement parts or non-production components.

L-824 – Underground Electrical Cable for Airport Lighting Circuits (AC 150/5345-7E)			
Manufacturer	Type	Voltage Rating	Manufacturer's Catalog Number
UNIKA UNIVERSAL	C	5000	TE <sub>x</sub> YBAP 8AWG; KE <sub>x</sub> YBAP 8AWG; TE <sub>x</sub> YPAP 8AWG; KE <sub>x</sub> YPAP 8AWG; TE <sub>x</sub> YBAY 8AWG; KE <sub>x</sub> YBAY 8AWG; TE <sub>x</sub> YPAY 8AWG; KE <sub>x</sub> YPAY 8AWG x = XLPE insulation

1. This Equipment requires continuing validation in accordance with the requirements of AC 150/5345-53, and the Intertek Airport Lighting Equipment Certification Program.
2. Product tested and Report issued by: Intertek; Cable Technology Laboratories

(A) Report No: 3192688CRT-001A; 3192688CRT-001B; 3192688SAT-018A; 3192688MID-019; P20102923; P20103134; 10-123

(B) Date of Report: 10/2010; 11/2010; 12/2010; 12/2010; 10/2010; 10/2010; 10/2010

NOTE: PLEASE REVIEW, AND ADVISE ADMINISTRATOR AT INTERTEK IMMEDIATELY IF DATA, AS SHOWN, NEED TO BE CORRECTED.

Approved for Certification by:

Jeremy N. Downs, PE, Program Administrator

Date: August 9, 2011