

# TYPE APPROVAL CERTIFICATE

Certificate no.:  
**TAE00000HX**  
Revision No:  
**4**

**This is to certify:**  
that the **Electric Power Cable**

with type designation(s)  
**U-HFA m, U-HFA m (C), U-HFA m EMC (VFD), U-HFA m EMC (VFD)**

issued to  
**Unika Universal Kablo San. ve Tic. A.S.**  
**ISTANBUL, Türkiye**

is found to comply with  
**DNV rules for classification – Ships, offshore units, and high speed and light craft**

## Application:

**General power and lighting. Screened. Electromagnetic interference Resistant.**  
Products approved by this certificate are accepted for installation on all vessels classed by DNV.

Type	Rated voltage (kV)	Temp. class (°C)
U-HFA m	0,6/1	90
U-HFA m (C)	0,6/1	90
U-HFA m EMC (VFD)	0,6/1	90
U-HFA m EMC (VFD)	1,8/3	90

Issued at **Høvik** on **2025-12-18**

This Certificate is valid until **2030-12-17**.

DNV local unit: **Istanbul**

Approval Engineer: **Ivar Bull**



for **DNV**

This document has been digitally signed and will  
therefore not have handwritten signature

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.  
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to USD 300 000.

### Product description

Type: U-HFA m & U-HFA m (C) & U-HFA m EMC (VFD) 0,6/1 kV;  
 U-HFA m EMC (VFD) 1,8/3 kV.

Construction:  
 Conductors: Plain or tinned stranded copper class 2 or class 5  
 Core insulation: XLPE  
 Inner covering: Halogen free filler or tape  
 Screen: Metal coated polyester tape (C)  
 Metal covering: Copper (plain or tinned) or  
 galvanized steel wire braid (multicore cables only)  
 Outer sheath: SHF1 or SHF2

#### 0,6/1 kV variants:

U-HFA m

No of cores:	Cross sectional area [mm <sup>2</sup> ]
1	1,0 – 300, 630
2	1,0 – 95
3	1,0 - 240
4	1,0 - 240
5G	10, 25, 50
5, 7, 8, 10, 12, 16, 18, 19, 24, 27, 37	1,0 - 2,5
6, 8, 9, 14, 15, 18, 25	1,5

U-HFA m (C) & U-HFA m EMC (VFD)

No of cores:	Cross sectional area [mm <sup>2</sup> ]
1	1,0 – 300
2	1,0 – 95
3	1,0 - 240
4	1,0 - 150
5G	10, 25, 50
5, 7, 10, 12, 16, 19, 24, 27, 37	1,0 - 2,5
3x+3x Cores	16+2,5 25+4 35+6 50+10 70+16 95+16 120+25 150+25 185+35 240+50

#### 1,8/3 kV variants:

U-HFA m EMC (VFD)

No of cores:	Cross sectional area [mm <sup>2</sup> ]
Single Core	10 16 25 35 50 70 95 120 150 185 240 300
3x+3x Cores	50+10 70+16 95+16 120+25 150+25 185+35 240+50

### Manufactured by

**Unika Universal Kablo San. ve Tic. A.S.**

No. 49 Yeni Sulun Sokak  
 80620 ISTANBUL  
 Turkey

### Application/Limitation

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

## Type Approval documentation

Data sheet and drawing U-HFA m  
 Data sheet and drawing U-HFA m (C)  
 Data sheets and drawings U-HFA m EMC  
 Electrical and physical routine test report No. 1031 dated 21.09.2007  
 Test report No. R5760/A/1, dated 2025-04-15  
 Renewal survey report dated 2025-12-01

## Tests carried out

Standard	Issued	General description	Limitation
IEC 60092-350	2020-01	General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-360	2021-01	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables.	
IEC 60092-353	2024-06	Electrical installations in ships - Part 353: Power cables for rated voltages 1 kV and 3 kV	
IEC 60332-3-22	2018-07	Tests on electric cables under fire conditions - Part 3-22: Test for vertical flame spread of vertical-mounted bunched wires or cables - Category A	Charred portion of sample does not exceed 2,5m above bottom edge of burner.
IEC 60754-1:2011 +AMD1:2019 CSV	2019-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen
IEC 60754-2:2011 +AMD1:2019 CSV	2019-11	Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity	Halogen free: pH > 4,3 Conductivity < 10µS/mm
IEC 61034-1&2:2005 +AMD1:2013 +AMD2:2019 CSV	2019-11	Measurement of smoke density of cables burning under defined conditions – Test apparatus, procedure and requirements	Low smoke Light transmittance >60%
IEC 60079-14	2024-08	Explosive atmospheres – Part 14: Electrical installation design, selection and installation of equipment, including initial inspection	Test acc. To Annex C. Only applicable for cable type U-HFA m

## Marking of product

UNIKA - year - Lot No - U-HFA m or U-HFA m (C) or U-HFA m EMC - size - 0,6/1kV - IEC 60092-353 - IEC 60332-3-22 or

UNIKA - year - Lot No - U-HFA m EMC - size - 1,8/3 kV - IEC 60092-353 - IEC 60332-3-22

## Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE